

Energy Audit Report

Introduction for Energy Audit:

In an organization Energy Audit is very much required for the systematic study of the energy consumption and its diurnal and seasonal variation. Also, the energy consumption of different devices/ equipment and components are made thoroughly and it is compared with the total energy consumption of the college. It is necessary to identify the faulty or higher energy consuming devices. If there is any leakage of energy in the old wiring, it is to be assessed and replacement is suggested. Another thing is the misuse or improper use of energy and the awareness of the stake holders, i.e., staff and students of the college is of utmost important. It is very much needed to reduce energy consumption through healthy practices, sustainable improvement and green energy generation. As per the suggestions of the audit the college authority considers the implementation of energy efficient devices and improved energy distribution policy. All the staff and students are encouraged to actively participate in the initiative.



SIR RASHBEHARI GHOSH MAHAVIDYALAYA has the practices for regular energy audit in the campus with an efficient internal audit team comprised of teachers and staff of the college, who are committed to audit the electrical installations, and the practices in the college with a sustainable goal. To evaluate the overall energy consumption, sustainability practices, and areas of improvement, the energy audit is conducted on a regular basis every year. Based on the findings and suggestions of the internal audit and on-site verification this report is prepared and necessary recommendations are made.



Executive Summary:



In accordance with the Format of Energy Audit and Evaluation Plan of SIR RASHBEHARI GHOSH MAHAVIDYALAYA, Ukhrid, Khandaghosh, Purba Bardhaman 713142 for the year 2023-'24 this audit was conducted in the month of November 2024.

Service Provided: Legal, Safety, Fire, Environment, Energy Audit and ISO, Information Security, Automotive, NABL, NABH, CSR, Food, Medical Certification and Training services
Govt.Reg.No.200252020048281, MSME Reg.No.UDYAM-WB-14-0014572, GST No. 19FIIPM3803A1ZH


Significant observation:

- College has prepared energy usage policy and the utilities. They have taken efforts for sustainable development strategy.
- College has formed an efficient audit team comprising of the teachers and staff of the college who conducts the study thoroughly and regularly and prepares a detailed report with specific suggestions.
- Installations of energy efficient star rated devices, LED lighting system is underway and they are in course of replacing all the old devices with the newer efficient devices.
- Some of the good practices of switching off the light and fans when not in use and installations of automatic switching system are suggested.



However, after detailed examinations of the report and physical verification it is noted that, some of the practices are required to be followed or added by the College in implementing the energy Policy of the institution and the applicable standards. In addition, certain processes could benefit from further review in order to improve their efficiency, fairness and consistency.

- Permissible Load
- Load distribution
- Energy consumption by the electrical appliances





MANAGEMENT SYSTEM CONSULTANCY

Service Provided: Legal, Safety, Fire, Environment, Energy Audit and ISO, Information Security, Automotive, NABL, NABH, CSR, Food, Medical Certification and Training services
Govt.Reg.No.200252020048281, MSME Reg.No.UDYAM-WB-14-0014572, GST No. 19FIIPM3803A1ZH

SL	Electrical Devices	Number	Power (Watt)	Usage Time (Hr / Day)
1	Normal Tube light	20	40watt	10 AM to 5 PM
2	LED Tube light	60	20watt	10 AM to 5 PM
3	Normal Bulb	02	60watt	10 AM to 5 PM
4	LED Bulb	17	09watt	10 AM to 5 PM
5	Ceiling Fan	79	52watt	10 AM to 5 PM
6	Stand Fan	02	160watt	10 AM to 5 PM
7	LED Metal	03	130watt	6 PM to 6 AM
8	Exhaust Fan	01	65watt	10 AM to 5 PM

Details of Water Consumption:

DESCRIPTION	2021-22	2022-23	2023-24
Capacity of Rain Water Harvesting	nil	nil	nil
Total Water Consumption	1757 lit	1993 lit	1801 lit
Total Water Bill	Rs 1180/-	Rs 1150/-	Rs 1120/-

Details of Energy Consumption:

DESCRIPTION	2021-22	2022-23	2023-24
Total energy generated on campus, including solar and others (in KWH)	nil	nil	nil
Total energy consumed based on electricity bill (in KWH)	2987 KW	3504 KW	3308 KW

Statement of Assurance:

In our professional judgment, as far as possible and appropriate audit procedures were completed and evidence gathered to support the accuracy of the conclusions reached and contained in this report. We hope that the time-to-time Energy Audit will provide an accurate snapshot of the college's betterment at this point in time, and that it will aid the campus in prioritizing positive steps it can take to improve overall sustainability. We intend this document to be revisited annually and updated by the college.

Recommendations:

UMA Apartment, Rishi Arobindo Road, Madhyamgram, Kolkata-700130

Email ID: managementsystemconsultancy@gmail.com

Website: www.managementsystemconsultancy.com



MANAGEMENT SYSTEM CONSULTANCY

Service Provided: Legal, Safety, Fire, Environment, Energy Audit and ISO, Information Security, Automotive, NABL, NABH, CSR, Food, Medical Certification and Training services
Govt.Reg.No.200252020048281, MSME Reg.No.UDYAM-WB-14-0014572, GST No. 19FIIPM3803A1ZH

College has established proper energy consumption strategy, but in view of modernization of laboratory and increase of infrastructure facility energy consumption is increasing. It is recommended to increase the facility of Solar PV system.

Amalish Kr. Mandal



MANAGEMENT SYSTEM CONSULTANCY

Authorization:

- National Safety Council Certified (EMS: Registered ID No. 20210701001, OH&S Auditor: Merit Certificate No. 20211013005)
- National Productivity Council Certified (Energy Management Auditor: Certificate No. N95P15C244453/EL/50)
- ISO 14001:2015 (Environment) (CQI-IRCA Delegate ID: 173839, Certificate No. 46957) Lead Auditor Certificate
- ISO 9001:2015 (Quality) (NABET Accredited, Certificate No. IRCLASS/QMS/2016/02/03/01 of 07) Lead Auditor Certificate
- ISO 45001:2018 (OHSAS) (CQI-IRCA Delegate ID: 111285, Certificate No. 44532) Lead Auditor Certificate.
- ISO 50001:2018 (Energy) (CQI-IRCA Delegate ID: 218048, Certificate No. ENR-00728617) Lead Auditor Certificate
- Certified PG Diploma in Environment and Sustainable Development (En Roll No-BU/13/706432) from Bundelkhand University.
- Certified PG Diploma in Fire and Safety Management from Jawaharlal Nehru Technological University Hyderabad (Cert. No. 15359120506)

Declaration

I agree with the all observations and recommendations mentioned in the report.


PRINCIPAL
Sir Rashbehari Ghosh Mahavidyalaya
Ukhrid (Khandaghoosh)
Purba Bardhaman, W.B.-713142

SIR RASHBEHARI GHOSH MAHAVIDYALAYA

UMA Apartment, Rishi Arobindo Road, Madhyamgram, Kolkata-700130

Email ID: managementsystemconsultancy@gmail.com

Website: www.managementsystemconsultancy.com